

Mac Haik Toyota - League City  
New Service Center Building

~~DO WE NEED WLE  
ON THIS LINE?  
THIS ONE HAS A  
BFP WITH LEAK  
DETECTOR  
METER~~

**EASEMENT NOT NEEDED;  
PRIVATE FIRE LINE SEPARATED  
FROM POTABLE LINE WITH  
BACK-FLOW PREVENTION  
DEVICE. J. LOTHROP 6/8/2017**

**Ownership of Instruments of Service:**  
All reports, plans, specifications, computer files, field data, notes & other documents and instruments prepared by Ryden Architecture, LLC as instruments of service shall remain the property of Ryden Architecture, LLC. Ryden Architecture, LLC shall retain all common law, statutory and other reserved rights, including the copyright thereto.

Issue:	
7/27/2016	PERMIT COMMENTS 1
8/16/2016	PERMIT COMMENTS 2
9/1/2016	PERMIT COMMENTS 3

---

Project No. FILENAME

# UTILITY PLAN C2.0