



Legislation Details (With Text)

File #:	18-0582	Version:	1	Name:	Base Construction Emergency Repair
Type:	Agenda Item	Status:		Status:	Approved
File created:	9/21/2018	In control:		In control:	Public Works
On agenda:	10/9/2018	Final action:		Final action:	10/9/2018
Title:	Consider and take action on a resolution to ratify the contract with Base Construction for the emergency repair of the 8-inch gravity sanitary sewer on State Highway 3 in an amount not to exceed \$82,375.00 (Director of Public Works)				

Sponsors:

Indexes:

Code sections:

Attachments: 1. Data Sheet, 2. Proposed Resolution, 3. Exhibit A - Agreement with Base Construction, 4. Report Card

Date	Ver.	Action By	Action	Result
10/9/2018	1	City Council	Approved	Pass

Consider and take action on a resolution to ratify the contract with Base Construction for the emergency repair of the 8-inch gravity sanitary sewer on State Highway 3 in an amount not to exceed \$82,375.00 (Director of Public Works)

Approval of this resolution will ratify the contract with Base Construction for the emergency repair of the 8-inch gravity sanitary sewer line on State Highway 3 in an amount not to exceed \$82,375.00.

On Wednesday September 12, 2018, city staff discovered a sinkhole in the median of State Highway 3 at the intersection with League Street. Upon further investigation, the sinkhole was found to be caused by a collapse in an 8-in gravity sanitary sewer line. A trench box was immediately placed in the hole to stabilize the area and prevent damage to the roadway. By-pass pumping operations were started to insure the continuation of sewer service to homes, businesses, and city offices and to avoid any overflows of sanitary sewer.

Due to the possible impact to public health and safety concerns and the high-risk threat of loss of sewer service to City buildings, this has been declared an emergency repair. Staff contacted three reputable contractors to evaluate and provide proposals and the results are as follows:

Base Construction Co.	\$ 82,375.00
David Wight Construction	\$ 97,828.00
D. Wagner Construction	No Estimate (Due to current work load)

Base Construction provided the lowest estimate in an amount not to exceed \$83,375.00 and was given the authorization to mobilize on-site beginning Monday, September 17, 2018. This prompt action ensured continued service to upstream customers and preserved public health and safety during the repair process. Base Construction Co. is expected to complete the repair within a week from mobilization.

Funds are available in the Line Repair Department's utility systems repair and maintenance budget line item No. 52620. Since the cost for this emergency repair exceeds \$50,000, it is necessary for the City Council to ratify the contract with Base Construction.

Attachments:

1. Data Sheet

2. Proposed Resolution
3. Exhibit A - Agreement with Base Construction
4. Report Card

FUNDING

{X} Funds are available from Account #10207700-52620 (Utility System & Repair)

STRATEGIC PLANNING

{X} NOT APPLICABLE