

Public Hearing

2023 MASTER WATER & WASTEWATER
PLANS UPDATE

Master Plan Updates

- Last Update was in 2018
- Study evaluated existing water and wastewater systems and the development of capacity and renewal recommendations for a 5-yr, 10-yr, and Buildout Capital Improvement Plan (CIP)

Water Master Plan Update

Over the last 10 years, the completion of water projects at SH 3, SSH, Calder Road., and Northside BPS, water system operations have stabilized, and special summer operational procedures have been reduced to localized pockets only during peak demand conditions.

Current system:

- approximately 2.86 million feet of mains in service.
- Main Sizes vary from 1” to 48” in diameter
- No low-pressure areas in system – can maintain 50psi all times of day.
- 10 Booster Pump Stations in use (10 to 54 years old).


Water Master Plan Update cont.

City has at present secured 28.044 MGD of water, but an additional 20.4 MGD is needed to meet projected demands at buildout.


City is working an agreement to reserve 20MGD of capacity from the SEWPP to help meet our long-term needs.

Although City has emergency well capacity, we are restricted to only 10% of the total annual water supply from groundwater sources without facing heavy monetary penalties from Harris-Galveston Subsidence District.

Water Master Plan Update cont.



Although City has emergency well capacity, we are restricted to only 10% of the total annual water supply from groundwater sources without facing heavy monetary penalties from Harris-Galveston Subsidence District.



The timing of projects shown is subject to change based on development patterns. The utility alignments shown in this figure are for illustration purposes only and do not set the alignments. The alignment of each utility will be determined at the time of the engineering design.

WasteWater Master Plan Update

Current system:

- approximately 1.98M feet of GM & 227K feet of FM in service.
- Main Sizes vary from 2" to 66" in diameter
- 78 Lift Stations
- 2 Water Reclamation Facilities

WasteWater Master Plan Update cont.

8.1.1 TCEQ Evaluation Criteria (75/90 Rule)

Lines showing the *recommended permitted average day flow (ADF) capacity, 90% of the permitted ADF capacity, and 75% of the permitted ADF capacity* are shown on **Figure 8-2** and **Figure 8-3**. These lines are based on TCEQ §305.126, commonly referred to as the 75/90 rule, which requires a WRF permit holder to begin planning for expansion of the treatment facility when the average day or average annual flow reaches 75% of the permitted capacity for three consecutive months. When the average day or average annual flow reaches 90% of the permitted capacity, the permit holder shall obtain necessary authorization from the commission to commence construction of the necessary additional treatment facilities.

8.1.2 Future Wastewater Treatment Capacity

The proposed treatment capacity expansions for each Wastewater Reclamation Facility are as follows:

- **Dallas Salmon:** No expansion of treatment capacity recommended.
- **Southwest:** Expansion of treatment capacity to 8.0 MGD by 2028 and further expansion of treatment capacity to 12.0 MGD in the Buildout planning period (after 2033).

These treatment capacity expansion recommendations were developed based on the projected average day wastewater flows, the capacity requirements in TCEQ §305.126, and a minimum period of 5-10 years before another projected expansion would be needed for the WRF.

Table 8-1: Proposed Wastewater Treatment Capacity

Water Reclamation Facility	Average Daily Permitted Treatment Capacity (MGD)			
	2023	2028	2033	Buildout
Dallas Salmon WRF	12.0	12.0	12.0	12.0
Southwest WRF	4.0	8.0	8.0	12.0
Total Treatment Capacity	16.0	20.0	20.0	24.0

WasteWater Master Plan Update cont.

Various combinations of improvements and modifications were investigated to assess the most appropriate approach for conveying the projected peak wastewater flows and treating the projected annual average wastewater flows. Considerations in developing the wastewater capacity CIP included increasing system reliability, simplifying system operations, conveying peak wet weather flows, and reducing surcharging and sanitary sewer overflows.

